

**SUMMARY OF ON-SITE AND OFF-SITE ODOR INSPECTIONS  
AND NUMBER OF TIMES ODOR WAS DETECTED AT THE VARIOUS MONITORING SITES**

<b>Month and year</b>	<b>Total Inspections</b>	<b>Entrance Gate (1)</b>	<b>Generator Bldg. (2)</b>	<b>Old Outfall (3)</b>	<b>UV Complex (4)</b>	<b>Solids Tanks (5)</b>	<b>Odor Scrubber (6)</b>	<b>Head-works (7)</b>	<b>Digesters (8)</b>	<b>UNC Bldg. (9)</b>
<b>Nov. 2008</b>	41	11	9	0	0	9	8	30	29	18
<b>Dec. 2008</b>	41	13	11	0	0	13	18	22	22	18
<b>Jan. 2009</b>	37	10	9	2	0	6	12	15	17	12
<b>Totals</b>	<b>119</b>	<b>34</b>	<b>29</b>	<b>2</b>	<b>0</b>	<b>28</b>	<b>38</b>	<b>67</b>	<b>68</b>	<b>48</b>
<b>%</b>		11%	9%	1%	0%	9%	12%	21%	22%	15%

**Notes:**

- 1) All on-site odor events were characterized by the WWTP Operators as “Mild” with odors that would not be expected to create an off-site problem.