

Emission Source/Operating Scenario Data Page 1 of 3

Boiler #7 - Operating Scenario #1 - CoalIf Emission Source has multiple Operating Scenarios, complete one form for each.
(All permitted, insignificant and/or Non-permitted Sources)Facility Name: University of North Carolina at Chapel HillFacility ID #: 6800043Permit #: 3069T17County: OrangeDAQ Region: RRO

North Carolina Department of Environment and Natural Resources

Division of Air Quality

Air Pollutant Point Source Emissions Inventory - Calendar Year 2004

1. Emission Source ID No. (same as in permit - Use "U" prefix for non-permitted and "I" for insignificant)		ES-002-Boiler #7	
2. Emission Source Description		Coal / Natural Gas / No. 2 Fuel Oil Fired Circulating Fluidized Bed Combustion - Steam Generating Unit	
3. Operating Scenario Description		Operating Scenario #1 - Coal	
4. Maximum Permitted Operating Rate With Units (Ex. gal/hr, mmBtu/hr)		323.17 MMBtu/hr	
5. Throughput in CY (e.g. production or fuel use) With Units (Ex. lbs/yr, gal/yr)		56,878 tons/yr	
6. Fuel Information (if fuel used)	% Sulfur	1.12%	% Ash 8.05% Heat Content (Btu/lb or mmCF) 13,068 Btu/lb

If you do not provide annual throughput/fuel use, your inventory will be deemed incomplete and returned to you.

7. Capture Efficiency (% Emissions from Emission Source Vented to Control Device or Stack)	100%
--	------

8. Control Device Information, if none, write "none"

	Control Device ID # (as listed in permit)	Control Device Description
i. (nearest stack)	CD-004	Bagfilter with Calcium Carbonate (CaCO ₃) Sorbent Injection
ii.	N/A	N/A
iii.	N/A	N/A
iv.	N/A	N/A

9. Stack Information (sources vented to more than one stack use additional entry lines)

Stack ID #	Height (in whole feet)	Diameter (feet) Circle (enter #), Rectangle (Lx, Wx) (in 0.1 feet)	Temperature (F)	Velocity (feet/sec)	Volume Flow Rate (acfm)	Release Point Description (Fugitive, Vertical, Vertical w/ cap, Horizontal, Downward - see instructions)
EP-14-136	220	9	305	56.1	214,000	Vertical
--	--	--	--	--	--	--
--	--	--	--	--	--	--

10. Operating Schedule (Source/Operating Scenario that best characterizes calendar year)

Hours/Day	24	Days/Week	7	Weeks/Year	50	Hours/Year	8,154 Total
Typical Start & End Times in CY:				Start:	N/A	End:	N/A

11. Seasonal Periods Percent Annual Throughput (for Emission Source in CY, MUST total 100%)

Jan-Feb, 2002 + Dec, 2002	33.86%	Mar-May	18.93%	June-Aug	22.13%	Sept-Nov	25.08%
------------------------------	--------	---------	--------	----------	--------	----------	--------

Emission Source/Operating Scenario Data Page 2 of 3

Boiler #7 - Operating Scenario #1 - Coal

If Emission Source has multiple Operating Scenarios, complete one form for each.
(All permitted, insignificant and/or Non-permitted Sources)

Facility Name:

University of North Carolina at Chapel Hill

Facility ID #: 6800043

Permit #: 3069T17

County: Orange

DAQ Region: RRO

North Carolina Department of Environment and Natural Resources

Division of Air Quality

Air Pollutant Point Source Emissions Inventory - Calendar Year 2004

Emissions: Attach calculations and documentation of emission factors or other estimation methods used.

Emission Source ID No. (same as in permit - Use "U" prefix for non-permitted and "I" for insignificant)

ES-002-Boiler #7

Criteria (NAAQS) Pollutants	Pollutant Code	Emissions Criteria (Tons/Year)	Emissions Estimation Method Code (see instructions for code)	Control Efficiency (Net after all controls)
Carbon Monoxide	CO	511.90	8	N/A
NOx	NOx	271.30	1	N/A
PM Total	PM	1.41	8	99.80%
PM-2.5	PM-2.5	0.84	8	97.90%
PM-10	PM-10	1.41	8	99.60%
SO2	SO2	101.33	1	90.00%
VOC	VOC	1.42	8	N/A
HAP/TAP Pollutants (In Alphabetical Order)	CAS # (or other code - see instructions)	Emissions HAP/TAP (Pounds/Year)	Emissions Estimation Method Code (see instructions for code)	Control Efficiency (Net after all controls)
Acetaldehyde	750-07-0	32.42	8	N/A
Acetophenone	98-86-2	0.85	8	N/A
Acrolein	107-02-8	16.49	8	N/A
Arsenic	ARSENICPDS	0.60	8	99.60%
Benzene	71-43-2	73.94	8	N/A
Benzo(a)pyrene	50-32-8	2.16E-03	8	N/A
Benzyl chloride	100-44-7	39.81	8	N/A
Beryllium	BERYLCPDS	27.95	8	N/A
Biphenyl	92-52-4	9.67E-02	8	N/A
Bis(2-ethylhexyl)phthalate (DEHP)	117-81-7	4.15	8	N/A
Bromine	7726-95-6	12.19	8	99.60%
Bromoform	75-25-2	2.22	8	N/A
Cadmium	CADMIUMCPDS	2.45E-02	8	99.60%
Carbon disulfide	75-10-0	7.39	8	N/A
2-Chloroacetophenone	532-27-4	0.40	8	N/A
Chlorobenzene	108-90-7	1.25	8	N/A
Chloroform	67-66-3	3.36	8	N/A
Chromium	CROMCPDS	0.96	8	99.60%
Chromium (VI)	CHROM6CPDS	0.96	8	99.60%
Cumene	98-82-8	0.30	8	N/A
Cyanide	CNC	142.19	8	N/A
Dibenzofurans	132-64-9	1.14E-02	8	N/A
Dimethyl sulfate	77-78-1	2.73	8	N/A
2,4-Dinitrotoluene	121-14-2	1.59E-02	8	N/A
Ethyl benzene	100-41-4	5.35	8	N/A
Ethyl chloride	75-00-3	2.39	8	N/A
Ethylene dibromide	106-93-4	6.83E-02	8	N/A
Ethylene dichloride	107-06-2	2.28	8	N/A

Emissions and data on this form required to report or verify emissions cannot be held confidential.

To review instructions or get a blank copy, go to web page: <http://daq.state.nc.us/Offices/Planning/Attainment/est.html>

Copy and Use additional Sheets as needed.

Emission Source/Operating Scenario Data Page 3 of 3

Boiler #7 - Operating Scenario #1 - Coal

If Emission Source has multiple Operating Scenarios, complete one form for each.
(All permitted, insignificant and/or Non-permitted Sources)

Facility Name:

University of North Carolina at Chapel Hill

Facility ID #: 6800043

Permit #: 3069T17

County: Orange

DAQ Region: RRO

North Carolina Department of Environment and Natural Resources

Division of Air Quality

Air Pollutant Point Source Emissions Inventory - Calendar Year 2004

Emissions: Attach calculations and documentation of emission factors or other estimation methods used.

Emission Source ID No. (same as in permit - Use "U" prefix for non-permitted and "I" for insignificant)

ES-002-Boiler #7

Criteria (NAAQS) Pollutants	Pollutant Code	Emissions Criteria (Tons/Year)	Emissions Estimation Method Code (see instructions for code)	Control Efficiency (Net after all controls)
Carbon Monoxide	CO	N/A	N/A	N/A
NOx	NOx	N/A	N/A	N/A
PM Total	PM	N/A	N/A	N/A
PM-2.5	PM-2.5	N/A	N/A	N/A
PM-10	PM-10	N/A	N/A	N/A
SO2	SO2	N/A	N/A	N/A
VOC	VOC	N/A	N/A	N/A
HAP/TAP Pollutants (In Alphabetical Order)	CAS # (or other code - see instructions)	Emissions HAP/TAP (Pounds/Year)	Emissions Estimation Method Code (see instructions for code)	Control Efficiency (Net after all controls)
Formaldehyde	50-0-00	13.65	8	N/A
Hexane	HEXANEISO	3.81	8	N/A
Hydrogen Chloride ***	7647-01-0	120011.84	8	90% Control with CaCO ₃
Hydrogen Fluoride ***	7664-39-3	2502.62	8	90% Control with CaCO ₃
Isophorone	78-59-1	32.99	8	N/A
Lead	LEADCPDS	0.39	8	99.60%
Manganese	MANGCPDS	1.66	8	99.60%
Mercury***	MERCCPDS	2.12	8	N/A
Methyl bromide	74-83-9	9.10	8	N/A
Methyl chloride	74-87-3	30.15	8	N/A
Methyl ethyl ketone	78-93-3	22.18	8	N/A
Methyl hydrazine	60-34-4	9.67	8	N/A
Methyl methacrylate	80-62-6	1.14	8	N/A
Methyl tert butyl ether	1634-04-4	1.99	8	N/A
Methylene chloride	75-09-2	16.49	8	N/A
Naphthalene	91-20-3	0.74	8	N/A
Nickel	NICKCPDS	0.79	8	99.60%
Phenol	108-95-2	0.91	8	N/A
POM	POM	3.33	8	N/A
Propionaldehyde	123-38-6	21.61	8	N/A
Styrene	100-42-5	1.42	8	N/A
2,3,7,8-TCDD	1746-01-6	8.13E-07	8	N/A
Tetrachloroethylene	79-34-5	2.45	8	N/A
Toluene	108-88-3	13.65	8	N/A
1,1,1-Trichloroethane	79-00-5	1.14	8	N/A
Vinyl acetate	108-05-4	0.43	8	N/A
Xylenes	1330-20-7	2.10	8	N/A

Emissions and data on this form required to report or verify emissions cannot be held confidential.

To review instructions or get a blank copy, go to web page: <http://daq.state.nc.us/Offices/Planning/Attainment/est.html>

Copy and Use additional Sheets as needed.

Emission Source/Operating Scenario Data Page 1 of 2

Boiler #7 - Operating Scenario #2 - Natural Gas
 If Emission Source has multiple Operating Scenarios, complete one form for each.
 (All permitted, insignificant and/or Non-permitted Sources)

Facility Name: University of North Carolina at Chapel Hill

Facility ID #: 6800043

Permit #: 3069T17

County: Orange

DAQ Region: RRO

North Carolina Department of Environment and Natural Resources

Division of Air Quality

Air Pollutant Point Source Emissions Inventory - Calendar Year 2004

1. Emission Source ID No. (same as in permit - Use "U" prefix for non-permitted and "I" for insignificant)					ES-002-Boiler #7	
2. Emission Source Description			Coal / Natural Gas / No. 2 Fuel Oil Fired Circulating Fluidized Bed Combustion - Steam Generating Unit			
3. Operating Scenario Description			Operating Scenario #2 - Natural Gas			
4. Maximum Permitted Operating Rate With Units (Ex. gal/hr, mmBtu/hr)			323.17 MMBtu/hr			
5. Throughput in CY (e.g. production or fuel use) With Units (Ex. lbs/yr, gal/yr)			3,425		1,000 ft ³ /yr	
6. Fuel Information (if fuel used)		% Sulfur	N/A	% Ash	N/A	Heat Content (Btu/lb or mmCF)
						1,030 Btu/ft ³

If you do not provide annual throughput/fuel use, your inventory will be deemed incomplete and returned to you.

7. Capture Efficiency (% Emissions from Emission Source Vented to Control Device or Stack)	100%
--	------

8. Control Device Information, if none, write "none"

	Control Device ID # (as listed in permit)	Control Device Description
i. (nearest stack)	CD-004	Bagfilter with Calcium Carbonate (CaCO ₃) Sorbent Injection
ii.	N/A	N/A
iii.	N/A	N/A
iv.	N/A	N/A

9. Stack Information (sources vented to more than one stack use additional entry lines)

Stack ID #	Height (in whole feet)	Diameter (feet) Circle (enter #), Rectangle (Lx, Wx) (in 0.1 feet)	Temperature (F)	Velocity (feet/sec)	Volume Flow Rate (acfm)	Release Point Description (Fugitive, Vertical, Vertical w/ cap, Horizontal, Downward - see instructions)
EP-14-136	220	9	305	56.1	214,000	Vertical
--	--	--	--	--	--	--
--	--	--	--	--	--	--

10. Operating Schedule (Source/Operating Scenario that best characterizes calendar year)

Hours/Day	24	Days/Week	7	Weeks/Year	50	Hours/Year	7,848 Total
Typical Start & End Times in CY:				Start:	N/A	End:	N/A

11. Seasonal Periods Percent Annual Throughput (for Emission Source in CY, MUST total 100%)

Jan-Feb, 2002 + Dec, 2002	1.46%	Mar-May	57.81%	June-Aug	9.93%	Sept-Nov	30.80%
------------------------------	-------	---------	--------	----------	-------	----------	--------

Facility ID #: 6800043
Permit #: 3069T17
County: Orange
DAO Region: RRO

Facility Name: University of North Carolina at Chapel Hill

North Carolina Department of Environment and Natural Resources
Division of Air Quality
Air Pollutant Point Source Emissions Inventory - Calendar Year 2004

Emissions: Attach calculations and documentation of emission factors or other estimation methods used.

Emission Source ID No. (same as in permit - Use "U" prefix for non-permitted and "I" for insignificant)

ES-002-Boiler #7[illegible]

Emissions and data on this form required to report or verify emissions cannot be held confidential.

To review instructions or get a blank copy, go to web page: <http://daq.state.nc.us/Offices/Planning/Attainment/est.html>

Copy and Use additional Sheets as needed.

Emission Source/Operating Scenario Data Page 1 of 2

Boiler #7 - Operating Scenario #3 - No. 6 Fuel Oil
 If Emission Source has multiple Operating Scenarios, complete one form for each.
 (All permitted, insignificant and/or Non-permitted Sources)

Facility Name: University of North Carolina at Chapel HillFacility ID #: 6800043Permit #: 3069T17County: OrangeDAQ Region: RRO

North Carolina Department of Environment and Natural Resources
Division of Air Quality
Air Pollutant Point Source Emissions Inventory - Calendar Year 2004

1. Emission Source ID No. (same as in permit - Use "U" prefix for non-permitted and "I" for insignificant)				ES-002-Boiler #7			
2. Emission Source Description		Coal / Natural Gas / No. 6 Fuel Oil Fired Circulating Fluidized Bed Combustion - Steam Generating Unit					
3. Operating Scenario Description		Operating Scenario #3 - No. 6 Fuel Oil					
4. Maximum Permitted Operating Rate With Units (Ex. gal/hr, mmBtu/hr)		323.17 MMBtu/hr					
5. Throughput in CY (e.g. production or fuel use) With Units (Ex. lbs/yr, gal/yr)				0 gallons/yr			
6. Fuel Information (if fuel used)		% Sulfur	2.10%	% Ash	0.10%	Heat Content (Btu/lb or mmCF)	150,000 Btu/gal

If you do not provide annual throughput/fuel use, your inventory will be deemed incomplete and returned to you.

7. Capture Efficiency (% Emissions from Emission Source Vented to Control Device or Stack)	100%
--	------

8. Control Device Information, if none, write "none"

	Control Device ID # (as listed in permit)	Control Device Description
i. (nearest stack)	CD-004	Bagfilter with Calcium Carbonate (CaCO ₃) Sorbent Injection
ii.	N/A	N/A
iii.	N/A	N/A
iv.	N/A	N/A

9. Stack Information (sources vented to more than one stack use additional entry lines)

Stack ID #	Height (in whole feet)	Diameter (feet) Circle (enter #), Rectangle (L#, W#) (in 0.1 feet)	Temperature (F)	Velocity (feet/sec)	Volume Flow Rate (acfm)	Release Point Description (Fugitive, Vertical, Vertical w/ cap, Horizontal, Downward - see instructions)
EP-14-136	220	9	305	56.1	214,000	Vertical
--	--	--	--	--	--	--
--	--	--	--	--	--	--

10. Operating Schedule (Source/Operating Scenario that best characterizes calendar year)

Hours/Day	0	Days/Week	0	Weeks/Year	0	Hours/Year	0
Typical Start & End Times in CY:				Start:	N/A	End:	N/A

11. Seasonal Periods Percent Annual Throughput (for Emission Source in CY, MUST total 100%)

Jan-Feb, 2002 + Dec, 2002	0.00%	Mar-May	#DIV/0!	June-Aug	#DIV/0!	Sept-Nov	#DIV/0!
------------------------------	-------	---------	---------	----------	---------	----------	---------

To review instructions or get a blank copy, go to web page: <http://daq.state.nc.us/Offices/Planning/Attainment/est.html>

Copy and Use additional Sheets as needed

University of North Carolina at Chapel Hill

North Carolina Department of Environment and Natural Resources
Division of Air Quality
Air Pollutant Point Source Emissions Inventory - Calendar Year 2004

Emissions: Attach calculations and documentation of emission factors or other estimation methods used.

Emission Source ID No. (same as in permit - Use "U" prefix for non-permitted and "I" for insignificant)

ES-002-Boiler #7[illegible]

Emissions and data on this form required to report or verify emissions cannot be held confidential.

To review instructions or get a blank copy, go to web page: <http://daq.state.nc.us/Offices/Planning/Attainment/est.html>

Copy and Use additional Sheets as needed.

Emission Source/Operating Scenario Data Page 1 of 2

Boiler #7 - Operating Scenario #4 - No. 2 Fuel OilIf Emission Source has multiple Operating Scenarios, complete one form for each.
(All permitted, insignificant and/or Non-permitted Sources)Facility Name: University of North Carolina at Chapel HillFacility ID #: 6800043Permit #: 3069T17County: OrangeDAQ Region: RRO

North Carolina Department of Environment and Natural Resources

Division of Air Quality

Air Pollutant Point Source Emissions Inventory - Calendar Year 2004

1. Emission Source ID No. (same as in permit - Use "U" prefix for non-permitted and "I" for insignificant)				ES-002-Boiler #7	
2. Emission Source Description		Coal / Natural Gas / No. 6 Fuel Oil Fired Circulating Fluidized Bed Combustion - Steam Generating Unit			
3. Operating Scenario Description		Operating Scenario #4 - No. 2 Fuel Oil			
4. Maximum Permitted Operating Rate With Units (Ex. gal/hr, mmBtu/hr)		323.17 MMBtu/hr			
5. Throughput in CY (e.g. production or fuel use) With Units (Ex. lbs/yr, gal/yr)		0 gallons/yr			
6. Fuel Information (if fuel used)		% Sulfur	0.50%	% Ash	Heat Content (Btu/lb or mmCF)
					137,006 Btu/gal

If you do not provide annual throughput/fuel use, your inventory will be deemed incomplete and returned to you.

7. Capture Efficiency (% Emissions from Emission Source Vented to Control Device or Stack)	100%
--	------

8. Control Device Information, if none, write "none"

	Control Device ID # (as listed in permit)	Control Device Description
i. (nearest stack)	CD-004	Bagfilter with Calcium Carbonate (CaCO ₃) Sorbent Injection
ii.	N/A	N/A
iii.	N/A	N/A
iv.	N/A	N/A

9. Stack Information (sources vented to more than one stack use additional entry lines)

Stack ID #	Height (in whole feet)	Diameter (feet) Circle (enter #), Rectangle (L#, W#) (in 0.1 feet)	Temperature (F)	Velocity (feet/sec)	Volume Flow Rate (acfm)	Release Point Description (Fugitive, Vertical, Vertical w/ cap, Horizontal, Downward - see instructions)
EP-14-136	220	9	305	56.1	214,000	Vertical
--	--	--	--	--	--	--
--	--	--	--	--	--	--

10. Operating Schedule (Source/Operating Scenario that best characterizes calendar year)

Hours/Day	24	Days/Week	7	Weeks/Year	50	Hours/Year	7,848 Total
Typical Start & End Times in CY:				Start:	N/A	End:	N/A

11. Seasonal Periods Percent Annual Throughput (for Emission Source in CY, MUST total 100%)

Jan-Feb, 2002 + Dec, 2002	#DIV/0!	Mar-May	#DIV/0!	June-Aug	#DIV/0!	Sept-Nov	#DIV/0!
------------------------------	---------	---------	---------	----------	---------	----------	---------

To review instructions or get a blank copy, go to web page: <http://daq.state.nc.us/Offices/Planning/Attainment/est.html>

Copy and Use additional Sheets as needed

University of North Carolina at Chapel Hill

Chapel Hill, North Carolina

Orange County

Facility ID # 6800043

Permit # 03069T17

2004 Annual Emissions Inventory

Boiler #7

(ES-002-Boiler #7)

Emissions Calculations

SO₂ and NO_x Emissions are Taken from CEMs data

HCl, HF, Hg emissions are based on stack test data

All other estimates are from DAQ Spreadsheets

Bituminous Coal Combustion

2004 Annual Emissions Inventory

Facility **University of North Carolina at Chapel Hill**
City **Chapel Hill**
County **Orange County**

APP #/Fac ID **6800043**
Input By **RST Engineering**
Source ID **Boiler #7**

Operating Scenario #1

(ES-002-Boiler #7)

Data Input

Maximum Heat Input mmBtu/hr

Boiler Size/Type

Actual Fuel Usage ton/yr

or

Hours of Operation hr/yr

and

Heating Value Btu/lb

ton/yr

Sulfur Content %

Ash Content : %

(B)ituminous or (S)ubbituminous? (B/S)

Calcium to Sulfur Ratio

Boiler Type:

- | | | |
|--------------------------|--------------------------------|-----------------------|
| 1) Pulverized/Dry Bottom | <input type="text" value="7"/> | 6) Underfeed Stoker |
| 2) Pulverized/Wet Bottom | | 7) Fluidized Bed Cir. |
| 3) Cyclone Furnace | | 8) Fluidized Bed Bub. |
| 4) Spreader Stoker | | 9) Hand Fed |
| 5) Overfeed Stoker | | |

Control Device Efficiencies:

PM	<input type="text" value="99.80"/>	%
PM-10	<input type="text" value="99.60"/>	%
PM-2.5	<input type="text" value="97.90"/>	%
SOx*	<input type="text" value="90.00"/>	%
NOx*	<input type="text" value="0.00"/>	%

**SOx and NOx emission estimates were calculated using CEMS data. Please refer to the SOx and NOx emissions data presented in the following CEMS spreadsheets.
HCl, HF, and Hg emissions based on stack test data.*

Bituminous Coal Combustion

2004 Annual Emissions Inventory

Facility University of North Carolina at Chapel Hill
City Chapel Hill
County Orange County

APP #/Fac ID 6800043
Input By RST Engineering
Source ID Boiler #7

Operating Scenario #1

(ES-002-Boiler #7)

ACTUAL CRITERIA EMISSIONS

Pollutant	Factor (lb poll./ton coal)	(lb/hr)	Emission Rates (lb/yr)	(tpy)
PM	17	0.61	2,821	1.41
PM-10	12.4	0.61	2,821	1.41
PM-2.5*	1.4	0.36	1,672	0.84
SO ₂	9.75	**	**	**
SO ₃ *	0.07	**	**	**
NO _x	3.90	**	**	**
VOC	0.05	0.62	2,844	1.42
CO	18	222.57	1,023,798	511.90

ACTUAL TOXIC EMISSIONS

Pollutant	Factor (lb poll./ton coal)	(lb/hr)	Emission Rates (lb/yr)	(tpy)
Acetaldehyde	5.70E-04	7.05E-03	3.24E+01	1.62E-02
Acetophenone	1.50E-05	1.85E-04	8.53E-01	4.27E-04
Acrolein	2.90E-04	3.59E-03	1.65E+01	8.25E-03
Arsenic	5.29E-03	1.31E-04	6.02E-01	3.01E-04
Benzene	1.30E-03	1.61E-02	7.39E+01	3.70E-02
Benzo(a)pyrene	3.80E-08	4.70E-07	2.16E-03	1.08E-06
Benzyl chloride	7.00E-04	8.66E-03	3.98E+01	1.99E-02
Beryllium	4.91E-04	6.08E-03	2.80E+01	1.40E-02
Biphenyl	1.70E-06	2.10E-05	9.67E-02	4.83E-05
Bis(2-ethylhexyl)phthalate (DEHP)	7.30E-05	9.03E-04	4.15E+00	2.08E-03
Bromine	1.07E-01	2.65E-03	1.22E+01	6.09E-03
Bromoform	3.90E-05	4.82E-04	2.22E+00	1.11E-03
Cadmium	2.15E-04	5.33E-06	2.45E-02	1.23E-05
Carbon disulfide	1.30E-04	1.61E-03	7.39E+00	3.70E-03
2-Chloroacetophenone	7.00E-06	8.66E-05	3.98E-01	1.99E-04
Chlorobenzene	2.20E-05	2.72E-04	1.25E+00	6.26E-04
Chloroform	5.90E-05	7.30E-04	3.36E+00	1.68E-03
Chromium	8.46E-03	2.09E-04	9.62E-01	4.81E-04
Chromium (VI)	8.46E-03	2.09E-04	9.62E-01	4.81E-04
Cumene	5.30E-06	6.55E-05	3.01E-01	1.51E-04
Cyanide	2.50E-03	3.09E-02	1.42E+02	7.11E-02
Dibenzofurans	2.01E-07	2.49E-06	1.14E-02	5.72E-06
Dimethyl sulfate	4.80E-05	5.94E-04	2.73E+00	1.37E-03
2,4-Dinitrotoluene	2.80E-07	3.46E-06	1.59E-02	7.96E-06
Ethyl benzene	9.40E-05	1.16E-03	5.35E+00	2.67E-03
Ethyl chloride	4.20E-05	5.19E-04	2.39E+00	1.19E-03
Ethylene dibromide	1.20E-06	1.48E-05	6.83E-02	3.41E-05
Ethylene dichloride	4.00E-05	4.95E-04	2.28E+00	1.14E-03
Formaldehyde	2.40E-04	2.97E-03	1.37E+01	6.83E-03
Hexane	6.70E-05	8.28E-04	3.81E+00	1.91E-03
Hydrogen Chloride ***	2.11E+00	2.61E+01	1.20E+05	6.00E+01
Hydrogen Fluoride ***	4.40E-02	5.44E-01	2.50E+03	1.25E+00
Isophorone	5.80E-04	7.17E-03	3.30E+01	1.65E-02
Lead	3.41E-03	8.44E-05	3.88E-01	1.94E-04

**SO₂ and NO_x emissions were estimated using CEMS data, please refer to the attached data sheets entitled "Sulfur Dioxide Emissions from Boiler #7" and Nitrogen Dioxide Emissions from Boiler #7".

*** HCl, HF, and Hg emissions based on stack test data.

Bituminous Coal Combustion

2004 Annual Emissions Inventory

Facility University of North Carolina at Chapel Hill
City Chapel Hill
County Orange County

APP #/Fac ID 6800043
Input By RST Engineering
Source ID Boiler #7

Operating Scenario #1

(ES-002-Boiler #7)

Actual Toxic Emissions (cont...)

Pollutant	Factor		Emission Rates	
	(lb poll./ton coal)	(lb/hr)	(lb/yr)	(tpy)
Manganese	1.48E-02	3.61E-04	1.66E+00	8.31E-04
Mercury***	3.73E-05	4.61E-04	2.12E+00	1.06E-03
Methyl bromide	1.60E-04	1.98E-03	9.10E+00	4.55E-03
Methyl chloride	5.30E-04	6.55E-03	3.01E+01	1.51E-02
Methyl ethyl ketone	3.90E-04	4.82E-03	2.22E+01	1.11E-02
Methyl hydrazine	1.70E-04	2.10E-03	9.67E+00	4.83E-03
Methyl methacrylate	2.00E-05	2.47E-04	1.14E+00	5.69E-04
Methyl tert butyl ether	3.50E-05	4.33E-04	1.99E+00	9.95E-04
Methylene chloride	2.90E-04	3.59E-03	1.65E+01	8.25E-03
Naphthalene	1.30E-05	1.61E-04	7.39E-01	3.70E-04
Nickel	6.95E-03	1.72E-04	7.91E-01	3.95E-04
Phenol	1.60E-05	1.98E-04	9.10E-01	4.55E-04
POM	5.85E-05	7.24E-04	3.33E+00	1.66E-03
Propionaldehyde	3.80E-04	4.70E-03	2.16E+01	1.08E-02
Styrene	2.50E-05	3.09E-04	1.42E+00	7.11E-04
2,3,7,8-TCDD	1.43E-11	1.77E-10	8.13E-07	4.07E-10
Tetrachloroethylene	4.30E-05	5.32E-04	2.45E+00	1.22E-03
Toluene	2.40E-04	2.97E-03	1.37E+01	6.83E-03
1,1,1-Trichloroethane	2.00E-05	2.47E-04	1.14E+00	5.69E-04
Vinyl acetate	7.60E-06	9.40E-05	4.32E-01	2.16E-04
Xylenes	3.70E-05	4.58E-04	2.10E+00	1.05E-03
Total HAPs		26.76	123,075.63	61.54

Version 5b-1.0k by Tony Pendola; 06/17/97

Notes:

- 1) Emission factors are from Supplement B to the 5th edition of AP-42, unless otherwise noted
- 2) Emission calculations will be based on the hours of operation only when actual fuel usage is not supplied
- 3) Particulate controls affect PM, PM-10, PM-2.5, and all toxics that are regulated as particulates except Mercury
- 4) VOC = NMTOC = TOC * (1-%METHANE)
- 5) PM-2.5 and SO3 do not currently need to be reported
- 6) Dibenzofurans = Polychlorinated dibenzo-p-furans
- 7) The Br emission factor is based on a mass balance generated from a 3 year coal analysis for Duke Power (1990-1992, 7 samples per year). The average concentration of bromine was 55.33 ppm (wet basis) and a heating value of 13,500 Btu/lb was assumed
- 8) For fluidized bed combustion the emission factor for underfeed stokers is utilized whenever the calcium-to-sulfur ratio is outside of the acceptable range of 1.5 to 7

Natural Gas Combustion Emissions Calculator NG2000 Revision C
2004 Annual Emissions Inventory
Boiler #7
(ES-002-Boiler #7)

Facility ID # 6800043
 Permit # 03069T17

Operating Scenario #2

User Input		Emissions Output (for operation 19.22 hr/yr)					Emission Factor (lb/mmcf)														
		Criteria Pollutants	lb/hr	lb/yr	tpy																
Company Name: University of North Carolina at Chapel Hill Plant County: Orange County Plant City: Chapel Hill Permit Number: 03069T17 User: TRC Environmental Corp. Heat Input Capacity (mmBtu/hr): 323.17 Fuel Input Capacity (10 ⁶ scf/hr): 0.32 Annual Fuel Throughput (10 ⁶ scf): 3.43 Latest Construction/Modification Date: N/A		PM	2.4E+00	2.6E+01	1.3E-02	7.6E+00															
		PM-10	2.4E+00	2.6E+01	1.3E-02	7.6E+00															
		PM-2.5	2.4E+00	2.6E+01	1.3E-02	7.6E+00															
		NOx	**	**	**	1.9E+02															
		VOC	1.7E+00	1.9E+01	9.4E-03	5.5E+00															
		CO	2.7E+01	2.9E+02	1.4E-01	8.4E+01															
		SO2	**	**	**	6.0E-01															
		Total HAP	6.0E-01	6.5E+00	3.2E-03	1.9E+00															
		Largest HAP	5.7E-01	6.2E+00	3.1E-03	1.8E+00															
		Enter the boiler type below ↓ 2		Toxic/Hazardous Air Pollutants																	
Pollutant	lb/hr			lb/day	lb/yr																
Arsenic	6.3E-05			NA	6.9E-04	2.0E-04															
Benzene	6.7E-04			NA	7.2E-03	2.1E-03															
Cadmium	3.5E-04			NA	3.8E-03	1.1E-03															
Chromium	4.4E-04			NA	4.8E-03	1.4E-03															
Chromium VI	4.4E-04			NA	4.8E-03	1.4E-03															
Dichlorobenzene	3.8E-04			NA	4.1E-03	1.2E-03															
Formaldehyde	2.4E-02			NA	2.6E-01	7.5E-02															
Hexane	5.7E-01			1.4E+01	6.2E+00	1.8E+00															
Lead	1.6E-04			NA	1.7E-03	5.0E-04															
Manganese	1.2E-04			2.9E-03	1.3E-03	3.8E-04															
Mercury	8.2E-05			2.0E-03	8.9E-04	2.6E-04															
Naphthalene	1.9E-04			NA	2.1E-03	6.1E-04															
Nickel	6.7E-04			1.6E-02	7.2E-03	2.1E-03															
POM	2.1E-04	NA	2.3E-03	6.6E-04																	
Toluene	1.1E-03	2.6E-02	1.2E-02	3.4E-03																	
Other NOx Control 4		Large Wall-Fired Boilers (≥100 mmBtu/hr) 1 = Uncontrolled (Pre-NSPS) 2 = Uncontrolled (Post-NSPS) 3 = Controlled - Low NOx burners 4 = Controlled - Flue gas recirculation (FGR)																			
							Small Boilers (<100 mmBtu/hr) 5 = Uncontrolled 6 = Controlled - Low NOx burners 7 = Controlled - Low NOx burners/FGR														
												Tangential-Fired Boilers (All Sizes) 8 = Uncontrolled 9 = Controlled - FGR									
																	Residential Furnaces (<0.3 mmBtu/hr) 10 = Uncontrolled				

** SOx and NOx emissions were estimated using CEMS data, please refer to the attached spreadsheets.
 Hourly emission rates for all pollutants based on hourly rated capacity.
 NG2000 Revision C dated March 9, 2000

Fuel Oil Combustion Emissions Calculator FO2000 Revision A
2004 Annual Emissions Inventory
Boiler #7
(ES-002-Boiler #7)
Facility ID # 6800043
Permit # 03069T17

Operating Scenario #3

User Input	
Company Name:	University of North Carolina at Chapel Hill
Plant County:	Orange County
Plant City:	Chapel Hill
Permit Number:	03069T17
User:	RST Engineering
Heat Input Capacity (mmBtu/hr):	323.17
Fuel Input Capacity (10 ³ gal/hr):	2.15
Annual Fuel Throughput (1000 gal):	0.00
Maximum fuel sulfur content (%):	2.1
Latest Construction/Modification Date:	N/A

Emissions Output

Criteria Pollutants

Pollutant	lb/hr ²	tpy	lb/yr ³	Emission Factor ¹ (lb/10 ³ gal)
Total PM (FPM + CPM)	3.7	0.0000	0	2.49E+01
Filterable PM (FPM) rates @ 99% control	0.5	0.0000	0	2.34E+01
Condensable PM (CPM) ⁴	3.2	0.0000	0	1.50E+00
Filterable PM-10 ⁵	0.4	0.0000	0	1.67E+01
Filterable PM-2.5 ⁵	0.3	0.0000	0	1.22E+01
NOx rates @ 39% control	**	**	**	4.70E+01
NMTOC	2	0.0000	0	7.60E-01
CO	11	0.0000	0	5.00E+00
SO2 rates @ 90% control	**	**	**	3.45E+02
Total HAP ⁶	3.92E-01	0.0000	0	1.82E-01
Largest HAP ⁶	1.82E-01	0.0000	0	8.45E-02

Toxic/Hazardous Air Pollutants.

Pollutant	lb/hr ²	lb/day ⁷	lb/yr ³	Emission Factor ¹ (lb/10 ³ gal)
Antimony rates @ 99% control	1.13E-04	NA	0.00E+00	5.25E-03
Arsenic rates @ 99% control	2.84E-05	NA	0.00E+00	1.32E-03
Benzene	4.61E-04	NA	0.00E+00	2.14E-04
Beryllium rates @ 99% control	5.99E-07	NA	0.00E+00	2.78E-05
Cadmium rates @ 99% control	8.57E-06	NA	0.00E+00	3.98E-04
Chromium rates @ 99% control	1.82E-05	NA	0.00E+00	8.45E-04
Chromium VI rates @ 99% control	5.34E-06	NA	0.00E+00	2.48E-04
Cobalt rates @ 99% control	1.30E-04	NA	0.00E+00	6.02E-03
Ethylbenzene	1.37E-04	NA	0.00E+00	6.36E-05
Fluoride	8.04E-02	1.93E+00	0.00E+00	3.73E-02
Formaldehyde	7.11E-02	1.71E+00	0.00E+00	3.30E-02
Lead rates @ 99% control	3.25E-05	NA	0.00E+00	1.51E-03
Manganese rates @ 99% control	6.46E-05	1.55E-03	0.00E+00	3.00E-03
Mercury	2.43E-04	5.84E-03	0.00E+00	1.13E-04
Methyl chloroform (1,1,1-Trichloroethane)	5.08E-04	1.22E-02	0.00E+00	2.36E-04
Naphthalene	2.43E-03	NA	0.00E+00	1.13E-03
Nickel rates @ 99% control	1.82E-03	4.37E-02	0.00E+00	8.45E-02
POM rates @ 99% control	1.31E-06	NA	0.00E+00	6.06E-05
Selenium rates @ 99% control	1.47E-05	NA	0.00E+00	6.83E-04
Toluene	1.34E-02	3.21E-01	0.00E+00	6.20E-03
Xylene	2.35E-04	5.64E-03	0.00E+00	1.09E-04

**Fuel Oil Combustion Emissions Calculator FO2000 Revision A
2004 Annual Emissions Inventory**

**Boiler #7
(ES-002-Boiler #7)
Facility ID # 6800043
Permit # 03069T17**

Operating Scenario #4 - No.2 Fuel Oil

User Input	
Company Name:	University of North Carolina at Chapel Hill
Plant County:	Orange County
Plant City:	Chapel Hill
Permit Number:	03069T17
User:	RST Engineering
Heat Input Capacity (mmBtu/hr):	323.17
Fuel Input Capacity (10 ³ gal/hr):	2.31
Annual Fuel Throughput (1000 gal):	0.00
Maximum fuel sulfur content (%):	0.5
Latest Construction/Modification Date:	N/A
Enter the boiler type below ▾	
15	

Boilers =>100 mmBtu/hr 1 = No. 6 oil fired, normal firing (U) 2 = No. 6 oil fired, normal firing (I) 3 = No. 6 oil fired, normal firing (C) 4 = No. 6 oil fired, normal firing, low NOx burner (U) 5 = No. 6 oil fired, normal firing, low NOx burner (I) 6 = No. 6 oil fired, normal firing, low NOx burner (C) 7 = No. 6 oil fired, tangential firing (U) 8 = No. 6 oil fired, tangential firing, low NOx burner (U) 9 = No. 5 oil fired, normal firing (U) 10 = No. 5 oil fired, normal firing (I) 11 = No. 5 oil fired, tangential firing (U) 12 = No. 4 oil fired, normal firing (U) 13 = No. 4 oil fired, normal firing (I) 14 = No. 4 oil fired, tangential firing (U) 15 = No. 2 oil fired (U,I)	Boilers =>100 mmBtu/hr (cont'd) 16 = No. 2 oil fired (C) 17 = No. 2 oil fired, LNB/FGR (U,I) 18 = No. 2 oil fired, LNB/FGR (C) 19 = Vertical fired utility boiler Small Boilers (<100 mmBtu/hr) 20 = No. 6 oil fired (I) 21 = No. 6 oil fired (C) 22 = No. 5 oil fired (C) 23 = No. 4 oil fired (C) 24 = No. 2 oil fired (I) 25 = No. 2 oil fired (C) 26 = Residential Furnace
---	--

Emission Controls

Particulate controls

Enter the control type below ▾	Message Area	Or enter a PM control efficiency below to override built in values.
3		
Control Device 0 = None/other 1 = ESP 2 = Scrubber 3 = Bagfilter 4 = Multiple cyclone	Avg. Cont. Effic. 99.0	User Input PM Cont. Effic. Message Area

Postcombustion SO₂ controls

Enter the control type below ▾	Message Area	Or enter an SO ₂ control efficiency below to override built in values.
0		
Control Technology/Process 0 = None/other 1 = Wet scrubber, Lime/limestone 2 = Wet scrubber, Sodium carbonate 3 = Wet scrubber, Magnesium oxide/hydroxide 4 = Wet scrubber, Dual alkali 5 = Spray drying, calcium hydroxide slurry, vap. in spray vessel 6 = Furnace injection, Dry calcium carbonate/hydrate inj. in upper furn. cavity 7 = Duct injection, Dry sorbent injection into duct, sometimes combined with water spray		User Input SO₂ Cont. Effic. 90.0 User entered control efficiency may be overestimated and should be documented.
	Avg. Cont. Effic. 0.0	
	Remarks NA	

NO_x controls

Enter the control type below ▾	Message Area	Or enter a NO _x control efficiency below to override built in values.
0		
Control Technology/Process 0 = None/other 1 = Low excess air (LEA) 2 = Staged combustion (SC) 3 = Burners out of service (BOOS) 4 = Flue gas recirculation (FGR) 5 = Flue gas recirculation plus staged combustion 6 = Low NO _x burners (LNB) 7 = Reduced air preheat (RAP) 8 = Selective noncatalytic reduction (SNCR) 9 = Conventional selective catalytic reduction (SCR)		User Input NO_x Cont. Effic. 0.0 Message Area
	Avg. Cont. Effic. 0.0	
	Remarks NA	

Emissions Output (for operation 6.79 hr/yr)

Criteria Pollutants				Emission Factor ¹ (lb/10 ³ gal)
Pollutant	lb/hr ²	tpy	lb/yr ³	
Total PM (FPM + CPM)	3.0	0.0000	0	3.30E+00
Filterable PM (FPM) rates @ 99% control	0.0	0.0000	0	2.00E+00
Condensable PM (CPM) ⁴	3.0	0.0000	0	1.30E+00
Filterable PM-10 ⁵	0.0	0.0000	0	1.00E+00
Filterable PM-2.5 ⁵	0.0	0.0000	0	2.50E-01
NO _x rates uncontrolled	**	**	**	2.40E+01
NMTOC	0	0.0000	0	2.00E-01
CO	12	0.0000	0	5.00E+00
SO ₂ rates @ 90% control	**	**	**	2.98E+02
Total HAP ⁶	4.17E-01	0.0000	0	1.81E-01
Largest HAP ⁶	1.84E-01	0.0000	0	7.97E-02

Toxic/Hazardous Air Pollutants.				Emission Factor ¹ (lb/10 ³ gal)
Pollutant	lb/hr ²	lb/day ⁷	lb/yr ³	
Antimony rates @ 99% control	0.00E+00	NA	0.00E+00	0.00E+00
Arsenic rates @ 99% control	1.29E-05	NA	0.00E+00	5.60E-04
Benzene	6.35E-03	NA	0.00E+00	2.75E-03
Beryllium rates @ 99% control	9.70E-06	NA	0.00E+00	4.20E-04
Cadmium rates @ 99% control	9.70E-06	NA	0.00E+00	4.20E-04
Chromium rates @ 99% control	9.70E-06	NA	0.00E+00	4.20E-04
Chromium VI rates @ 99% control	2.85E-06	NA	0.00E+00	1.23E-04
Cobalt rates @ 99% control	0.00E+00	NA	0.00E+00	0.00E+00
Ethylbenzene	1.89E-03	NA	0.00E+00	8.17E-04
Fluoride	8.61E-02	2.07E+00	0.00E+00	3.73E-02
Formaldehyde	1.11E-01	2.66E+00	0.00E+00	4.80E-02
Lead rates @ 99% control	2.91E-05	NA	0.00E+00	1.26E-03

Manganese rates @ 99% control	1.94E-05	4.85E-04	0.00E+00	8.40E-04
Mercury	9.70E-04	2.33E-02	0.00E+00	4.20E-04
Methyl chloroform (1,1,1-Trichloroethane)	5.45E-04	1.31E-02	0.00E+00	2.36E-04
Napthalene	7.69E-04	NA	0.00E+00	3.33E-04
Nickel rates @ 99% control	9.70E-06	2.33E-04	0.00E+00	4.20E-04
POM rates @ 99% control	7.62E-05	NA	0.00E+00	3.30E-03
Selenium rates @ 99% control	4.85E-05	NA	0.00E+00	2.10E-03
Toluene	1.84E-01	4.41E+00	0.00E+00	7.97E-02
Xylene	3.23E-03	7.76E-02	0.00E+00	1.40E-03

¹Emission factors represent AP-42 uncontrolled values. Emission rates are reflective of controls where applicable.

²Hourly emission rates for all pollutants are based on hourly rated capacity.

³Annual emission rates for all pollutants are based on maximum annual fuel throughput.

⁴Wet scrubbers are assumed to control CPM whereas other PM control devices are assumed to only control FPM.

⁵AP-42 assumes PM-10 and PM-2.5 assumes these pollutants are controlled with the same efficiency as total PM.

⁶Total and largest HAP factors and emission rates do not reflect control of metals. Individual metal emission rates are reflective of particulate matter controls where applicable.

⁷Daily emission rates are based on operation 24 hours per day at rated capacity.

**SO₂ and NO_x emissions were estimated using CEMS data, please refer to the attached spreadsheets.

FO2000 Revision A dated March 9, 2000

University of North Carolina at Chapel Hill

Chapel Hill, North Carolina

Orange County

Facility ID # 6800043

Permit # 03069T17

2004 Annual Emissions Inventory

Sulfur Dioxide Emissions from Boiler #7

(ES-002-Boiler #7)

The exhaust duct at Boiler #7 is equipped with a continuous emissions monitor (CEMs) for SO₂ emissions.

For the 2004 calendar year, 30 day facility averages for the SO₂ emission rate measured by the CEM are as follows:

Month	30 day average CEM reading (lb/MMBtu)
January 2004	0.146
February 2004	0.138
March 2004	0.139
April 2004	0.138
May 2004	0.178
June 2004	0.139
July 2004	0.135
August 2004	0.136
September 2004	0.106
October 2004	0.123
November 2004	0.127
December 2004	0.128
Annual Average	0.136

This average includes SO₂ emissions from coal, fuel oil, and natural gas within Boiler #6 over the entire year, representing a composite average for all fuels combusted.

Fuel Inputs to Boiler #7 for 2004.

Boiler #7			
Coal Tons/yr	Gas 1,000cf/yr	No. 6 Oil Gallons/yr	No. 2 Oil Gallons/yr
56,878	3,425	0	0
Coal (13,068 btu/lb)	Nat. Gas (1,030 btu/cf)	Oil (150,000 btu/gal)	Oil (137,006 btu/gal)
MMBtu/year			
1.49E+06	3.53E+03	0.00E+00	0.00E+00

Total for Boiler #7 (MMBtu/yr)	1.49E+06
--------------------------------	----------

Total SO ₂ Emissions from Boiler #7 (lb/yr)	202,651
Total SO ₂ Emissions from Boiler #7 (ton/yr)	101.3

SO ₂ Emissions Associated with Coal Combustion (ton/yr)	101.3
SO ₂ Emissions Associated with No. 6 Fuel Oil Combustion (ton/yr)	0.0
SO ₂ Emissions Associated with No. 2 Fuel Oil Combustion (ton/yr)	0.00

University of North Carolina at Chapel Hill

Chapel Hill, North Carolina

Orange County

Facility ID # 6800043

Permit # 03069T17

2004 Annual Emissions Inventory**Nitrogen Dioxide Emissions from Boiler #7****(ES-002-Boiler #7)**

The exhaust duct at Boiler #7 is equipped with a continuous emissions monitor (CEMs) for NOx emissions. For the 2004 calendar year, 30 day facility averages for the NOx emission rate measured by the CEM are as follows:

Month	30 day average CEM reading (lb/MMBtu)
January 2004	0.49
February 2004	0.46
March 2004	0.35
April 2004	0.33
May 2004	0.31
June 2004	0.33
July 2004	0.29
August 2004	0.30
September 2004	0.30
October 2004	0.40
November 2004	0.40
December 2004	0.42
Annual Average	0.37

This average includes NOx emissions from coal, fuel oil, and natural gas within Boiler #7 over the entire year, representing a composite average for all fuels combusted.

Fuel Inputs to Boiler #7 for 2004

Boiler #7			
Coal Tons/yr	Gas 1,000cf/yr	No. 6 Oil Gallons/yr	No. 2 Oil Gallons/yr
56,878	3,425	0	0
Coal (13,068 btu/lb)	Nat. Gas (1,030 btu/cf)	Oil (150,000 btu/gal)	Oil (137,006 btu/gal)
MMBtu/year			
1.49E+06	3.53E+03	0.00E+00	0.00E+00

Total for Boiler #7 (MMBtu/yr)	1.49E+06
--------------------------------	----------

NOx Emissions from Boiler #7 (lb/yr)	543,880
NOx Emissions from Boiler #7 (ton/yr)	271.9

NOx Emissions Associated with Coal Combustion (ton/yr)	271.30
NOx Emissions Associated with Fuel Oil No. 6 Combustion (ton/yr)	0.0
NOx Emissions Associated with Fuel Oil No. 2 Combustion (ton/yr)	0.00
NOx Emissions Associated with Natural Gas Combustion (ton/yr)	0.64

University of North Carolina at Chapel Hill

Chapel Hill, North Carolina

Orange County

Facility ID # 6800043

Permit # 03069T17

2004 Annual Emissions Inventory

Boiler #8

(ES-003-Boiler #8)

Operating Scenario #1 - Natural Gas Firing
Operating Scenario #2 - No. 2 Fuel Oil Firing

Emission Source/Operating Scenario Data Page 1 of 1

Boiler #8 - Operating Scenario #1 - Natural Gas
 If Emission Source has multiple Operating Scenarios, complete one form for each.
 (All permitted, insignificant and/or Non-permitted Sources)

Facility Name: University of North Carolina at Chapel Hill

Facility ID #: 6800043

Permit #: 3069T17

County: Orange

DAQ Region: RRO

North Carolina Department of Environment and Natural Resources

Division of Air Quality

Air Pollutant Point Source Emissions Inventory - Calendar Year 2004

1. Emission Source ID No. (same as in permit - Use "U" prefix for non-permitted and "I" for insignificant)					ES-003-Boiler #8	
2. Emission Source Description			Natural Gas / No. 2 Fuel Oil Fired Boiler			
3. Operating Scenario Description			Operating Scenario #1 - Natural Gas			
4. Maximum Permitted Operating Rate With Units (Ex. gal/hr, mmBtu/hr)			338.0 MMBtu/hr			
5. Throughput in CY (e.g. production or fuel use) With Units (Ex. lbs/yr, gal/yr)			94,162		1,000 ft ³ /yr	
6. Fuel Information (if fuel used)		% Sulfur	N/A	% Ash	N/A	Heat Content (Btu/lb or mmCF)
						1,030 Btu/ft ³

If you do not provide annual throughput/fuel use, your inventory will be deemed incomplete and returned to you.

7. Capture Efficiency (% Emissions from Emission Source Vented to Control Device or Stack)	N/A
--	-----

8. Control Device Information, if none, write "none"

	Control Device ID # (as listed in permit)	Control Device Description
i. (nearest stack)	None	None
ii.	None	None
iii.	None	None
iv.	None	None

9. Stack Information (sources vented to more than one stack use additional entry lines)

Stack ID #	Height (in whole feet)	Diameter (feet) Circle (enter #), Rectangle (L#, W#) (in 0.1 feet)	Temperature (F)	Velocity (feet/sec)	Volume Flow Rate (acfm)	Release Point Description (Fugitive, Vertical, Vertical w/ cap, Horizontal, Downward - see instructions)
EP-4	208	6	300	47.2	80073	Boiler Stack
--	--	--	--	--	--	--
--	--	--	--	--	--	--

10. Operating Schedule (Source/Operating Scenario that best characterizes calendar year)

Hours/Day	Standby	Days/Week	Standby	Weeks/Year	Standby	Hours/Year	1,833 Total
Typical Start & End Times in CY:				Start:	N/A	End:	N/A

11. Seasonal Periods Percent Annual Throughput (for Emission Source in CY, MUST total 100%)

Jan-Feb, 2002 + Dec, 2002	3%	Mar-May	42%	June-Aug	2%	Sept-Nov	53%
------------------------------	----	---------	-----	----------	----	----------	-----

To review instructions or get a blank copy, go to web page: <http://daq.state.nc.us/Offices/Planning/Attainment/est.html>

Copy and Use additional Sheets as needed

Emission Source/Operating Scenario Data Page 1 of 1

Boiler #8 - Operating Scenario #2 - No. 2 Fuel Oil
 If Emission Source has multiple Operating Scenarios, complete one form for each.
 (All permitted, insignificant and/or Non-permitted Sources)

Facility Name: University of North Carolina at Chapel HillFacility ID #: 6800043Permit #: 3069T17County: OrangeDAQ Region: RRO

North Carolina Department of Environment and Natural Resources

Division of Air Quality

Air Pollutant Point Source Emissions Inventory - Calendar Year 2004

1. Emission Source ID No. (same as in permit - Use "U" prefix for non-permitted and "I" for insignificant)				ES-003-Boiler #8	
2. Emission Source Description		Natural Gas / No. 2 Fuel Oil Fired Boiler			
3. Operating Scenario Description		Operating Scenario #2 - No. 2 Fuel Oil			
4. Maximum Permitted Operating Rate With Units (Ex. gal/hr, mmBtu/hr)		338.0 MMBtu/hr			
5. Throughput in CY (e.g. production or fuel use) With Units (Ex. lbs/yr, gal/yr)			133,691 gallons/year		
6. Fuel Information (if fuel used)	% Sulfur	0.50%	% Ash		Heat Content (Btu/lb or mmCF) 135,344 Btu/gal

If you do not provide annual throughput/fuel use, your inventory will be deemed incomplete and returned to you.

7. Capture Efficiency (% Emissions from Emission Source Vented to Control Device or Stack)	N/A
--	-----

8. Control Device Information, if none, write "none"

	Control Device ID # (as listed in permit)	Control Device Description
i. (nearest stack)	N/A	N/A
ii.	N/A	N/A
iii.	N/A	N/A
iv.	N/A	N/A

9. Stack Information (sources vented to more than one stack use additional entry lines)

Stack ID #	Height (in whole feet)	Diameter (feet) Circle (enter #), Rectangle (L x W) (in 0.1 feet)	Temperature (F)	Velocity (feet/sec)	Volume Flow Rate (acfm)	Release Point Description (Fugitive, Vertical, Vertical w/ cap, Horizontal, Downward - see instructions)
EP-4	208	6	300	47.2	80073	Boiler Stack
--	--	--	--	--	--	--
--	--	--	--	--	--	--

10. Operating Schedule (Source/Operating Scenario that best characterizes calendar year)

Hours/Day	Standby	Days/Week	Standby	Weeks/Year	Standby	Hours/Year	1,833 Total
Typical Start & End Times in CY:				Start:	N/A	End:	N/A

11. Seasonal Periods Percent Annual Throughput (for Emission Source in CY, MUST total 100%)

Jan-Feb, 2002 + Dec, 2002	100%	Mar-May	0%	June-Aug	0%	Sept-Nov	0%
------------------------------	------	---------	----	----------	----	----------	----

To review instructions or get a blank copy, go to web page: <http://daq.state.nc.us/Offices/Planning/Attainment/est.html>

Copy and Use additional Sheets as needed

Natural Gas Combustion Emissions Calculator NG2000 Revision C
2004 Annual Emissions Inventory
Boiler #8
(ES-003-Boiler #8)

Facility ID # 6800043
 Permit # 03069T17

Operating Scenario #1

User Input		Emissions Output				Emission
Company Name: Plant County: Plant City: Permit Number: User: Heat Input Capacity (mmBtu/hr): Fuel Input Capacity (10 ⁶ scf/hr): Annual Fuel Throughput (10 ⁶ scf): Latest Construction/Modification Date:	University of North Carolina at Chapel Hill Orange County Chapel Hill 03069T17 RST Engineering 338 0.33 94.16 N/A	Criteria Pollutants				F factor (lb/nm ³ scf)
		Pollutant	lb/hr	lb/yr	tpy	
		PM	2.5E+00	7.2E+02	3.6E-01	7.6E+00
		PM-10	2.5E+00	7.2E+02	3.6E-01	7.6E+00
		PM-2.5	2.5E+00	7.2E+02	3.6E-01	7.6E+00
		NOx	**	**	**	1.9E+02
		VOC	1.8E+00	5.2E+02	2.6E-01	5.5E+00
		CO	2.8E+01	7.9E+03	4.0E+00	8.4E+01
		SO2	2.0E-01	5.6E+01	2.8E-02	6.0E-01
		Total HAP	6.3E-01	1.8E+02	8.9E-02	1.9E+00
		Largest HAP	6.0E-01	1.7E+02	8.5E-02	1.8E+00
Enter the boiler type below ▾ <div style="border: 1px solid black; width: 100px; text-align: center; margin-top: 5px;">3 + 4</div>						
Other NOx Control Enter 1 below if SNCR is applied to the boiler. <div style="border: 1px solid black; width: 100px; text-align: center; margin-top: 5px;">0</div>						
Large Wall-Fired Boilers (≥100 mmBtu/hr) 1 = Uncontrolled (Pre-NSPS) 2 = Uncontrolled (Post-NSPS) 3 = Controlled - Low NOx burners 4 = Controlled - Flue gas recirculation (FGR)						
Small Boilers (<100 mmBtu/hr) 5 = Uncontrolled 6 = Controlled - Low NOx burners 7 = Controlled - Low NOx burners/FGR						
Tangential-Fired Boilers (All Sizes) 8 = Uncontrolled 9 = Controlled - FGR						
Residential Furnaces (<0.3 mmBtu/hr) 10 = Uncontrolled						
		Toxic/Hazardous Air Pollutants				
		Pollutant	lb/hr	lb/day	lb/yr	
		Arsenic	6.6E-05	NA	1.9E-02	2.0E-04
		Benzene	7.0E-04	NA	2.0E-01	2.1E-03
		Cadmium	3.6E-04	NA	1.0E-01	1.1E-03
		Chromium	4.6E-04	NA	1.3E-01	1.4E-03
		Chromium VI	4.6E-04	NA	1.3E-01	1.4E-03
		Dichlorobenzene	4.0E-04	NA	1.1E-01	1.2E-03
		Formaldehyde	2.5E-02	NA	7.1E+00	7.5E-02
		Hexane	6.0E-01	1.4E+01	1.7E+02	1.8E+00
		Lead	1.7E-04	NA	4.7E-02	5.0E-04
		Manganese	1.3E-04	3.0E-03	3.6E-02	3.8E-04
		Mercury	8.6E-05	2.1E-03	2.4E-02	2.6E-04
		Naphthalene	2.0E-04	NA	5.7E-02	6.1E-04
		Nickel	7.0E-04	1.7E-02	2.0E-01	2.1E-03
		POM	2.2E-04	NA	6.2E-02	6.6E-04
		Toluene	1.1E-03	2.7E-02	3.2E-01	3.4E-03
		** NOx emissions were estimated using CEMS data, please refer to the attached spreadsheets. Hourly emission rates for all pollutants based on hourly rated capacity. NG2000 Revision C dated March 9, 2000				

Fuel Oil Combustion Emissions Calculator FO2000 Revision A**Boiler #8****2004 Annual Emissions Inventory****(ES-003-Boiler #8)****Facility ID # 6800043****Permit # 03069T17****Operating Scenario #2****User Input**

Company Name:	University of North Carolina at Chapel Hill
Plant County:	Orange County
Plant City:	Chapel Hill
Permit Number:	03069T17
User:	RST Engineering
Heat Input Capacity (mmBtu/hr):	338
Fuel Input Capacity (10³ gal/hr):	2.41
Annual Fuel Throughput (1000 gal):	133.69
Maximum fuel sulfur content (%):	0.50
Latest Construction/Modification Date:	N/A

Enter the boiler type below ↘**17****Boilers =>100 mmBtu/hr**

- 1 = No. 6 oil fired, normal firing (U)
- 2 = No. 6 oil fired, normal firing (I)
- 3 = No. 6 oil fired, normal firing (C)
- 4 = No. 6 oil fired, normal firing, low NOx burner (U)
- 5 = No. 6 oil fired, normal firing, low NOx burner (I)
- 6 = No. 6 oil fired, normal firing, low NOx burner (C)
- 7 = No. 6 oil fired, tangential firing (U)
- 8 = No. 6 oil fired, tangential firing, low NOx burner (U)
- 9 = No. 5 oil fired, normal firing (U)
- 10 = No. 5 oil fired, normal firing (I)
- 11 = No. 5 oil fired, tangential firing (U)
- 12 = No. 4 oil fired, normal firing (U)
- 13 = No. 4 oil fired, normal firing (I)
- 14 = No. 4 oil fired, tangential firing (U)
- 15 = No. 2 oil fired (U,I)

Boilers =>100 mmBtu/hr (cont'd)

- 16 = No. 2 oil fired (C)
- 17 = No. 2 oil fired, LNB/FGR (U,I)
- 18 = No. 2 oil fired, LNB/FGR (C)

19 = Vertical fired utility boiler**Small Boilers (<100 mmBtu/hr)**

- 20 = No. 6 oil fired (I)
- 21 = No. 6 oil fired (C)
- 22 = No. 5 oil fired (C)
- 23 = No. 4 oil fired (C)
- 24 = No. 2 oil fired (I)
- 25 = No. 2 oil fired (C)

26 = Residential Furnace

Fuel Oil Combustion Emissions Calculator FO2000 Revision A

Boiler #8

2004 Annual Emissions Inventory

(ES-003-Boiler #8)

Facility ID # 6800043

Permit # 03069T17

Operating Scenario #2

User Input	
Company Name:	University of North Carolina at Chapel Hill
Plant County:	Orange County
Plant City:	Chapel Hill
Permit Number:	03069T17
User:	RST Engineering
Heat Input Capacity (mmBtu/hr):	338
Fuel Input Capacity (10 ³ gal/hr):	2.41
Annual Fuel Throughput (1000 gal):	133.69
Maximum fuel sulfur content (%)	0.50
Latest Construction/Modification Date:	N/A

Emission Controls

Particulate controls

Enter the control type below ▾	Message Area	Or enter a PM control efficiency below to override built in values.
0		
<u>Control Device</u> 0 = None/other 1 = ESP 2 = Scrubber 3 = Bagfilter 4 = Multiple cyclone	<u>Avg. Cont. Effic.</u> 0.0 0.0	<u>User Input PM Cont. Effic.</u> 0.0 Message Area

Postcombustion SO₂ controls

Enter the control type below ▾	Message Area	Or enter an SO ₂ control efficiency below to override built in values.
0		
<u>Control Technology/Process</u> 0 = None/other 1 = Wet scrubber, Lime/limestone 2 = Wet scrubber, Sodium carbonate 3 = Wet scrubber, Magnesium oxide/hydroxide 4 = Wet scrubber, Dual alkali 5 = Spray drying, calcium hydroxide slurry, vap. in spray vessel 6 = Furnace injection, Dry calcium carbonate/hydrate inj. in upper furn. cavity 7 = Duct injection, Dry sorbent injection into duct, sometimes combined with water spray	<u>Avg. Cont. Effic.</u> 0.0 <u>Remarks</u> NA	<u>User Input SO₂ Cont. Effic.</u> 0.0 Message Area

NO_x controls

Enter the control type below ▾	Message Area	Or enter a NO _x control efficiency below to override built in values.
5 + 6		
<u>Control Technology/Process</u> 0 = None/other 1 = Low excess air (LEA) 2 = Staged combustion (SC) 3 = Burners out of service (BOOS) 4 = Flue gas recirculation (FGR) 5 = Flue gas recirculation plus staged combustion 6 = Low NO _x burners (LNB) 7 = Reduced air preheat (RAP) 8 = Selective noncatalytic reduction (SNCR)	<u>Avg. Cont. Effic.</u> 0.0 <u>Remarks</u> NA	<u>User Input NO_x Cont. Effic.</u> 0.0 Message Area

Fuel Oil Combustion Emissions Calculator FO2000 Revision A

Boiler #8

2004 Annual Emissions Inventory

(ES-003-Boiler #8)

Facility ID # 6800043

Permit # 03069T17

Operating Scenario #2

User Input	
Company Name:	University of North Carolina at Chapel Hill
Plant County:	Orange County
Plant City:	Chapel Hill
Permit Number:	03069T17
User:	RST Engineering
Heat Input Capacity (mmBtu/hr):	338
Fuel Input Capacity (10 ³ gal/hr):	2.41
Annual Fuel Throughput (1000 gal):	133.69
Maximum fuel sulfur content (%)	0.50
Latest Construction/Modification Date:	N/A

Emissions Output

Criteria Pollutants

Pollutant	lb/hr ²	tpy	lb/yr ³	Emission Factor ¹ (lb/10 ³ gal)
Total PM (FPM + CPM)	8.0	0.2206	441	3.30E+00
Filterable PM (FPM) rates uncontrolled	4.8	0.1337	267	2.00E+00
Condensable PM (CPM) ⁴	3.1	0.0869	174	1.30E+00
Filterable PM-10 ⁵	2.4	0.0668	134	1.00E+00
Filterable PM-2.5 ⁵	0.6	0.0167	33	2.50E-01
NOx rates uncontrolled	**	**	**	2.40E+01
NMTOC	0	0.0134	27	2.00E-01
CO	12	0.3342	668	5.00E+00
SO2 rates uncontrolled	59.2	1.6377	3,275	2.45E+01
Total HAP ⁶	4.36E-01	0.0121	24	1.81E-01
Largest HAP ⁶	1.92E-01	0.0053	11	7.97E-02

**NOx emissions based on CEMs data.

Toxic/Hazardous Air Pollutants.

Pollutant	lb/hr ²	lb/day ⁷	lb/yr ³	Emission Factor ¹ (lb/10 ³ gal)
Antimony rates uncontrolled	0.00E+00	NA	0.00E+00	0.00E+00
Arsenic rates uncontrolled	1.35E-03	NA	7.49E-02	5.60E-04
Benzene	6.64E-03	NA	3.68E-01	2.75E-03
Beryllium rates uncontrolled	1.01E-03	NA	5.62E-02	4.20E-04
Cadmium rates uncontrolled	1.01E-03	NA	5.62E-02	4.20E-04
Chromium rates uncontrolled	1.01E-03	NA	5.62E-02	4.20E-04
Chromium VI rates uncontrolled	2.98E-04	NA	1.65E-02	1.23E-04
Cobalt rates uncontrolled	0.00E+00	NA	0.00E+00	0.00E+00
Ethylbenzene	1.97E-03	NA	1.09E-01	8.17E-04
Fluoride	9.01E-02	2.16E+00	4.99E+00	3.73E-02
Formaldehyde	1.16E-01	2.78E+00	6.42E+00	4.80E-02
Lead rates uncontrolled	3.04E-03	NA	1.68E-01	1.26E-03
Manganese rates uncontrolled	2.03E-03	4.87E-02	1.12E-01	8.40E-04
Mercury	1.01E-03	2.43E-02	5.62E-02	4.20E-04
Methyl chloroform (1,1,1-Trichloroethane)	5.70E-04	1.37E-02	3.16E-02	2.36E-04
Naphthalene	8.04E-04	NA	4.45E-02	3.33E-04
Nickel rates uncontrolled	1.01E-03	2.43E-02	5.62E-02	4.20E-04
POM rates uncontrolled	7.97E-03	NA	4.41E-01	3.30E-03
Selenium rates uncontrolled	5.07E-03	NA	2.81E-01	2.10E-03
Toluene	1.92E-01	4.62E+00	1.07E+01	7.97E-02
Xylene	3.38E-03	8.12E-02	1.87E-01	1.40E-03

Fuel Oil Combustion Emissions Calculator FO2000 Revision A**Boiler #8****2004 Annual Emissions Inventory****(ES-003-Boiler #8)****Facility ID # 6800043****Permit # 03069T17****Operating Scenario #2**

User Input	
Company Name:	University of North Carolina at Chapel Hill
Plant County:	Orange County
Plant City:	Chapel Hill
Permit Number:	03069T17
User:	RST Engineering
Heat Input Capacity (mmBtu/hr):	338
Fuel Input Capacity (10 ³ gal/hr):	2.41
Annual Fuel Throughput (1000 gal):	133.69
Maximum fuel sulfur content (%)	0.50
Latest Construction/Modification Date:	N/A

¹Emission factors represent AP-42 uncontrolled values. Emission rates are reflective of controls where applicable.

²Hourly emission rates for all pollutants are based on hourly rated capacity.

³Annual emission rates for all pollutants are based on maximum annual fuel throughput.

⁴Wet scrubbers are assumed to control CPM whereas other PM control devices are assumed to only control FPM.

⁵AP-42 assumes PM-10 and PM-2.5 assumes these pollutants are controlled with the same efficiency as total PM.

⁶Total and largest HAP factors and emission rates do not reflect control of metals. Individual metal emission rates are reflective of particulate matter controls where applicable.

⁷Daily emission rates are based on operation 24 hours per day at rated capacity.

SO₂ and NO_x emissions were estimated using CEMS data, please refer to the attached spreadsheets.

FO2000 Revision A dated March 9, 2000

University of North Carolina at Chapel Hill

Chapel Hill, North Carolina

Orange County

Facility ID # 6800043

Permit # 03069T17

2004 Annual Emissions Inventory

Nitrogen Dioxide Emissions from Boiler #8

(ES-003-Boiler #8)

The exhaust duct at Boiler #8 is equipped with a continuous emissions monitor (CEMs) for NOx emissions. For the 2004 calendar year, 30 day facility averages for the NOx emission rate measured by the CEM are as follows:

Month	30 day average CEM reading (lb/MMBtu)
January 2004	0.06
February 2004	0.06
March 2004	0.06
April 2004	0.06
May 2004	0.05
June 2004	0.05
July 2004	0.05
August 2004	0.05
September 2004	0.05
October 2004	0.07
November 2004	0.07
December 2004	0.07
Annual Average	0.07

This average includes NOx emissions from coal, fuel oil, and natural gas within Boiler #8 over the entire year, representing a composite average for all fuels combusted.

Fuel Inputs to Boiler #8 for 2004

Boiler #8	
Gas 1,000cf/yr	Oil Gallons/yr
94,162	133,691
Nat. Gas (1,030 btu/cf)	Oil (137,006 btu/gal)
MMBtu/yr	
9.70E+04	1.83E+04

Total for Boiler #8 (MMBtu/yr)	1.15E+05
--------------------------------	----------

NOx Emissions from Boiler #8 (lb/yr)	8,071
NOx Emissions from Boiler #8 (ton/yr)	4.0

NOx Emissions Associated with Fuel Oil Combustion (ton/yr)	0.64
NOx Emissions Associated with Natural Gas Combustion (ton/yr)	3.39

University of North Carolina at Chapel Hill

Chapel Hill, North Carolina

Orange County

Facility ID # 6800043

Permit # 03069T17

2004 Annual Emissions Inventory

**Coal Crusher/Conveyor Building
(ES-010A)**